



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

Laboratory Report

Merrimack Village Dist
2 Greens Pond Rd
Merrimack, NH 03054

Date Printed: 03/04/2025
Work Order #: 2502-03087
Client Job #:
Date Received: 02/20/2025
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- ND: Non-detect. Results reported as Non-Detect (ND) have been evaluated down to the concentration listed in the MDL column.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: J = Estimated concentration.**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



Donald A. D'Anjou, Ph. D.
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-001
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-008 (MVD-2)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:47PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroicosafuoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	0.709	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF30NS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorobutanesulfonic Acid (PFBS)*	4.17	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorobutanoic Acid (PFBA)*	3.36	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-001
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-008 (MVD-2)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:47PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoroheptanoic acid (PFHpA)*	4.27	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorohexanesulfonic Acid (PFHxS)*	1.51	ng/L	✓	J	2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorohexanoic acid (PFHxA)*	5.88	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorooctanesulfonic acid (PFOS)*	2.98	ng/L	✓		2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluorooctanoic acid (PFOA)*	19.3	ng/L	✕		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoropentanoic acid (PFPeA)*	4.43	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:30PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	94	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-001
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-008 (MVD-2)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:47PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[13C8]octanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Perfluoro-n-[13C9]nonanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	93	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	103	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	101	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Sodium perfluoro-[13C8]octanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	101	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	101	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:30PM



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-002
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-012 (MVD 9)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:48PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorobutanesulfonic Acid (PFBS)*	1.33	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorobutanoic Acid (PFBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-002
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-012 (MVD 9)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:48PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorooctanesulfonic acid (PFOS)*	0.647	ng/L	✓	J	2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluorooctanoic acid (PFOA)*	1.92	ng/L	✓	J	2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:43PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	93	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-002
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-012 (MVD 9)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:48PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[13C8]octanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Perfluoro-n-[13C9]nonanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	92	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Sodium perfluoro-[13C8]octanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:43PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-003
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-512 (TP-2/9)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:49PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorobutanesulfonic Acid (PFBS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorobutanoic Acid (PFBA)*	0.679	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-003
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-512 (TP-2/9)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:49PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluorooctanoic acid (PFOA)*	<2.00	ng/L	✓		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 04:57PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	93	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-003
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-512 (TP-2/9)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:49PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	94	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	94	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[13C8]octanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Perfluoro-n-[13C9]nonanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	105	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	104	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Sodium perfluoro-[13C8]octanesulfonate	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	104	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 04:57PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-004
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-011 (MVD-4R)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:10PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	0.623	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorobutanesulfonic Acid (PFBS)*	7.73	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorobutanoic Acid (PFBA)*	7.13	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-004
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-011 (MVD-4R)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:10PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoroheptanoic acid (PFHpA)*	18.7	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorohexanesulfonic Acid (PFHxS)*	3.29	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorohexanoic acid (PFHxA)*	22.7	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorononanoic acid (PFNA)*	0.797	ng/L	✓	J	2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorooctanesulfonic acid (PFOS)*	5.45	ng/L	✓		2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluorooctanoic acid (PFOA)*	110	ng/L	✕		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoropentanesulfonic acid (PFPeS)*	0.920	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoropentanoic acid (PFPeA)*	14.3	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:11PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	101	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	94	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-004
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-011 (MVD-4R)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:10PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	94	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	93	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[13C8]octanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Perfluoro-n-[13C9]nonanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	128	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	101	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Sodium perfluoro-[13C8]octanesulfonate	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	99	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:11PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-005
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-005 (MVD-5)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:11PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	0.720	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorobutanesulfonic Acid (PFBS)*	5.97	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorobutanoic Acid (PFBA)*	5.83	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-005
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-005 (MVD-5)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:11PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoroheptanoic acid (PFHpA)*	12.0	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorohexanesulfonic Acid (PFHxS)*	2.53	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorohexanoic acid (PFHxA)*	16.5	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorooctanesulfonic acid (PFOS)*	1.97	ng/L	✓	J	2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluorooctanoic acid (PFOA)*	60.6	ng/L	✕		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoropentanesulfonic acid (PFPeS)*	0.779	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoropentanoic acid (PFPeA)*	10.5	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:24PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-005
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-005 (MVD-5)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:11PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	99	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[13C8]octanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Perfluoro-n-[13C9]nonanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	103	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Sodium perfluoro-[13C8]octanesulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	103	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	105	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:24PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-006
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-509 (TP-4/5)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:08PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorobutanesulfonic Acid (PFBS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorobutanoic Acid (PFBA)*	0.892	ng/L		J	2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-006
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-509 (TP-4/5)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:08PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluorooctanoic acid (PFOA)*	<2.00	ng/L	✓		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 05:38PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	80	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	87	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	87	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	86	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	85	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-006
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-509 (TP-4/5)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 12:08PM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	84	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	84	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	88	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[13C8]octanoic acid	85	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Perfluoro-n-[13C9]nonanoic acid	86	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Sodium perfluoro-[13C8]octanesulfonate	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 05:38PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-007
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-007 (MVD-7)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:08AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF30NS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorobutanesulfonic Acid (PFBS)*	2.57	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorobutanoic Acid (PFBA)*	2.70	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-007
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-007 (MVD-7)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:08AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoroheptanoic acid (PFHpA)*	3.39	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorohexanoic acid (PFHxA)*	3.16	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorooctanesulfonic acid (PFOS)*	3.16	ng/L	✓		2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluorooctanoic acid (PFOA)*	25.1	ng/L	✕		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoropentanoic acid (PFPeA)*	2.17	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:05PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	94	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	93	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-007
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-007 (MVD-7)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:08AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	99	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	85	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[13C8]octanoic acid	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Perfluoro-n-[13C9]nonanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	108	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Sodium perfluoro-[13C8]octanesulfonate	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	101	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:05PM



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-008
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-009 (MVD-8)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:15AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorobutanesulfonic Acid (PFBS)*	2.32	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorobutanoic Acid (PFBA)*	2.13	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-008
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-009 (MVD-8)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:15AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoroheptanoic acid (PFHpA)*	3.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorohexanesulfonic Acid (PFHxS)*	1.33	ng/L	✓	J	2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorohexanoic acid (PFHxA)*	2.96	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorooctanesulfonic acid (PFOS)*	1.62	ng/L	✓	J	2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluorooctanoic acid (PFOA)*	21.4	ng/L	✕		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoropentanoic acid (PFPeA)*	2.01	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:19PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	88	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-008
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-009 (MVD-8)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:15AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	85	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[13C8]octanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Perfluoro-n-[13C9]nonanoic acid	92	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	135	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	105	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Sodium perfluoro-[13C8]octanesulfonate	98	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	99	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:19PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-009
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-510 (TP-7/8)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:30AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Date Extracted	-					No Limit	EPA 533	TF-NH	02/21/2025 08:51AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorobutanesulfonic Acid (PFBS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorobutanoic Acid (PFBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-009
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-510 (TP-7/8)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:30AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluorooctanoic acid (PFOA)*	<2.00	ng/L	✓		2.00	12 ng/L	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	DL-NH	02/28/2025 06:32PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	92	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	93	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	100	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 03/04/2025
SAMPLE ID #: 2502-03087-009
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2025
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-510 (TP-7/8)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/19/2025 11:30AM
DATE & TIME RECEIVED: 02/20/2025 09:20AM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 6.9° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	95	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	91	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[13C8]octanoic acid	97	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Perfluoro-n-[13C9]nonanoic acid	96	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	136	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	106	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	105	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Sodium perfluoro-[13C8]octanesulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	102	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	105	%	✓			50-200%	EPA 533 - IDA	DL-NH	02/28/2025 06:32PM



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
 Phone: (800) 699-9920 | (603) 432-3044 | website: www.granitestateanalytical.com

CHAIN OF CUSTODY

2602-3087
 WORK ORDER#: _____

DUE DATE: _____

COMPANY Merrimack Village District
 ADDRESS 2 Greens Pond Road
Merrimack, NH 03054
 PHONE# (603) 424-9241 x103 Fax# (603) 424-0563
 P.O.# 3885
 CLIENT CONTACT Jill Lavoie
 PROJECT LOCATION/STATE: Merrimack, NH
 EMAIL jill.lavoie@mvdwater

CONTAINER TYPE
 P-PLASTIC
 G-GLASS
 SAMPLE TYPE
 1. Water 5. Tissue
 2. Soil 6. Other
 3. Sudge
 4. Oil

ANALYSES									
PFAS Method 533 7241003G									

#	SAMPLE IDENTIFICATION	SAMPLE TYPE	CONTAINER			SAMPLING		PRESERVATIVE	COMMENTS
			SIZE	TYPE	#	DATE	TIME		
1	1531010-008 (MVD-2)	1		P	2	2/19/2025	1247	X	-001
2	1531010_012 (MVD 9)	1		P	2	2/19/2025	1248	X	-002
3	1531010-512 (TP- 2/9)	1		P	2	2/19/2025	1249	X	-003
4	1531010-011 (MVD-4R)	1		P	2	2/19/2025	1210	X	-004
5	1531010_005 (MVD-5)	1		P	2	2/19/2025	1211	X	-005
6	1531010_509 (TP-4/5)	1		P	2	2/19/2025	1208	X	-006
7	1531010_007 (MVD-7)	1		P	2	2/19/2025	1108	X	-007
8	1531010_009 (MVD-8)	1		P	2	2/19/2025	1115	X	-008
9	1531010_510 (TP-7/8)	1		P	2	2/19/2025	1130	X	-009

Turn Around Time: <input type="checkbox"/> RUSH _____ Day TAT <input type="checkbox"/> ROUTINE	SAMPLED BY: <u>Ronald Harvey</u> RELINQUISHED BY: <u>Steph Chase</u> RELINQUISHED BY: _____	DATE: <u>2/19/25</u> TIME: <u>1323</u> DATE: <u>2-20-25</u> TIME: <u>9:20</u> DATE: _____ TIME: _____	RECEIVED BY: _____ RECEIVED BY: _____ RECEIVED FOR LAB BY: <u>[Signature]</u> DATE: <u>25 FEB 20</u> 9:20 AM TIME: _____
	Temp: <u>6.9</u> °C on ice (Y/N)	METHOD OF SHIPMENT: _____	SPECIAL INSTRUCTIONS: RAW AND TREATED WATER SAMPLES