

Laboratory Report

Merrimack Village Dist
2 Greens Pond Rd
Merrimack, NH 03054

Date Printed: 01/30/2026
Work Order #: 2601-03446
Client Job #:
Date Received: 01/20/2026
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

Eurofins Auburn:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210

Eurofins Derry:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038

Eurofins Ayer:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- ND: Non-detect. Results reported as Non-Detect (ND) have been evaluated down to the concentration listed in the MDL column.
- Eurofins Derry, Eurofins Auburn and Eurofins Ayer's accreditations can be found on the website below.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: J = Estimated concentration.**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



Donald A. D'Anjou, Ph. D.
Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-001
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-008 (MVD-2 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 02:15PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF30NS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorobutanesulfonic Acid (PFBS)*	3.30	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorobutanoic Acid (PFBA)*	2.86	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-001
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-008 (MVD-2 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 02:15PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoroheptanoic acid (PFHpA)*	3.60	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorohexanesulfonic Acid (PFHxS)*	1.07	ng/L	✓	J	2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorohexanoic acid (PFHxA)*	4.60	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorooctanesulfonic acid (PFOS)*	2.90	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluorooctanoic acid (PFOA)*	19.1	ng/L	✗		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoropentanoic acid (PFPeA)*	3.23	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:16PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	83	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	98	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	102	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	79	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	94	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-001
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-008 (MVD-2 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 02:15PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	98	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	99	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[13C8]octanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Perfluoro-n-[13C9]nonanoic acid	99	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	136	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	73	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Sodium perfluoro-[13C8]octanesulfonate	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	113	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:16PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-002
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-012 (MVD 9 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 02:16PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorobutanesulfonic Acid (PFBS)*	1.01	ng/L		J	2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorobutanoic Acid (PFBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-002
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-012 (MVD 9 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 02:16PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluorooctanoic acid (PFOA)*	1.83	ng/L	✓	J	2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:30PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	109	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	101	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-002
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-012 (MVD 9 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 02:16PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	109	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	105	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	102	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[13C8]octanoic acid	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Perfluoro-n-[13C9]nonanoic acid	106	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	142	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	74	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Sodium perfluoro-[13C8]octanesulfonate	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	111	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	102	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:30PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-003
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-512 (TP-2/9 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:56PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorobutanesulfonic Acid (PFBS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorobutanoic Acid (PFBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-003
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-512 (TP-2/9 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:56PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluorooctanoic acid (PFOA)*	<2.00	ng/L	✓		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:44PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	84	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	94	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	100	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	97	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	95	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-003
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-512 (TP-2/9 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:56PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	94	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[13C8]octanoic acid	92	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Perfluoro-n-[13C9]nonanoic acid	95	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	106	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	98	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	73	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Sodium perfluoro-[13C8]octanesulfonate	101	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	107	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	105	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:44PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-004
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-011 (MVD-4R raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:21PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorobutanesulfonic Acid (PFBS)*	6.57	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorobutanoic Acid (PFBA)*	6.06	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-004
SAMPLED BY: Merrimack Village Dist
SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-011 (MVD-4R raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE & TIME COLLECTED: 01/20/2026 01:21PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoroheptanoic acid (PFHpA)*	12.9	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorohexanesulfonic Acid (PFHxS)*	3.19	ng/L	✓		2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorohexanoic acid (PFHxA)*	18.0	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorononanoic acid (PFNA)*	0.669	ng/L	✓	J	2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorooctanesulfonic acid (PFOS)*	4.54	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluorooctanoic acid (PFOA)*	79.2	ng/L	✕		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoropentanesulfonic acid (PFPeS)*	0.755	ng/L		J	2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoropentanoic acid (PFPeA)*	11.3	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 05:57PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	78	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	92	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	92	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	80	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	86	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-004
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-011 (MVD-4R raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:21PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	93	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	94	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[13C8]octanoic acid	88	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Perfluoro-n-[13C9]nonanoic acid	86	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	86	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	122	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	68	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Sodium perfluoro-[13C8]octanesulfonate	102	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	109	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	102	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 05:57PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-005
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-005 (MVD-5 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:22PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorobutanesulfonic Acid (PFBS)*	5.83	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorobutanoic Acid (PFBA)*	5.71	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-005
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-005 (MVD-5 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:22PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoroheptanoic acid (PFHpA)*	9.81	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorohexanesulfonic Acid (PFHxS)*	2.75	ng/L	✓		2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorohexanoic acid (PFHxA)*	14.0	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorooctanesulfonic acid (PFOS)*	1.99	ng/L	✓	J	2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluorooctanoic acid (PFOA)*	52.6	ng/L	✗		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoropentanoic acid (PFPeA)*	9.64	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:11PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	82	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	100	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	106	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	83	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	94	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-005
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-005 (MVD-5 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:22PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	95	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	97	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	100	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[13C8]octanoic acid	98	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Perfluoro-n-[13C9]nonanoic acid	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	87	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	123	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	69	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Sodium perfluoro-[13C8]octanesulfonate	105	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	110	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:11PM




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-006
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-509 (TP-4/5 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:15PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorobutanesulfonic Acid (PFBS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorobutanoic Acid (PFBA)*	1.52	ng/L		J	2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-006
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-509 (TP-4/5 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:15PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluorooctanoic acid (PFOA)*	<2.00	ng/L	✓		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:25PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	66	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	79	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	80	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	68	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	69	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-006
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-509 (TP-4/5 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 01:15PM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	62	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	69	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	81	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[13C8]octanoic acid	69	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Perfluoro-n-[13C9]nonanoic acid	73	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	109	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	88	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	67	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Sodium perfluoro-[13C8]octanesulfonate	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	110	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	109	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:25PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-007
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-007 (MVD-7 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:05AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorobutanesulfonic Acid (PFBS)*	2.95	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorobutanoic Acid (PFBA)*	2.72	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-007
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-007 (MVD-7 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:05AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoroheptanoic acid (PFHpA)*	3.21	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorohexanesulfonic Acid (PFHxS)*	1.64	ng/L	✓	J	2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorohexanoic acid (PFHxA)*	2.71	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorooctanesulfonic acid (PFOS)*	3.04	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluorooctanoic acid (PFOA)*	25.9	ng/L	✗		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoropentanoic acid (PFPeA)*	2.26	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:38PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	86	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	97	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	82	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	95	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-007
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-007 (MVD-7 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:05AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	102	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	100	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[13C8]octanoic acid	100	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Perfluoro-n-[13C9]nonanoic acid	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	92	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	166	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	80	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Sodium perfluoro-[13C8]octanesulfonate	103	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	107	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	97	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:38PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-008
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-009 (MVD-8 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:08AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorobutanesulfonic Acid (PFBS)*	2.40	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorobutanoic Acid (PFBA)*	2.06	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-008
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-009 (MVD-8 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:08AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoroheptanoic acid (PFHpA)*	3.02	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorohexanesulfonic Acid (PFHxS)*	1.21	ng/L	✓	J	2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorohexanoic acid (PFHxA)*	2.81	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorooctanesulfonic acid (PFOS)*	1.47	ng/L	✓	J	2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluorooctanoic acid (PFOA)*	23.6	ng/L	✗		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoropentanoic acid (PFPeA)*	2.11	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 06:52PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	85	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	92	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	84	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	98	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-008
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-009 (MVD-8 raw)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:08AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	110	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	93	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[13C8]octanoic acid	99	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Perfluoro-n-[13C9]nonanoic acid	96	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	176	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	86	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Sodium perfluoro-[13C8]octanesulfonate	110	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	113	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 06:52PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-009
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-510 (TP-7/8 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:18AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Date Extracted	-					No Limit	EPA 533	TF-NH	01/22/2026 08:12AM
Hexafluoropropylene oxide dimer acid (HFPO-DA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoro-3-methoxypropanoic acid (PFMPA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoro-4-methoxybutanoic acid (PFMBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorobutanesulfonic Acid (PFBS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorobutanoic Acid (PFBA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-009
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-510 (TP-7/8 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:18AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluorodecanoic Acid (PFDA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorododecanoic acid (PFDoA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoroheptanesulfonic acid (PFHpS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoroheptanoic acid (PFHpA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorohexanesulfonic Acid (PFHxS)*	<2.00	ng/L	✓		2.00	18 ng/L	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorohexanoic acid (PFHxA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorononanoic acid (PFNA)*	<2.00	ng/L	✓		2.00	11 ng/L	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorooctanesulfonic acid (PFOS)*	<2.00	ng/L	✓		2.00	15 ng/L	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluorooctanoic acid (PFOA)*	<2.00	ng/L	✓		2.00	12 ng/L	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoropentanesulfonic acid (PFPeS)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoropentanoic acid (PFPeA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
Perfluoroundecanoic acid (PFUnA)*	<2.00	ng/L			2.00	No Limit	EPA 533	SH-NH	01/22/2026 07:06PM
2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid	81	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	92	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	99	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 01/30/2026
SAMPLE ID #: 2601-03446-009
SAMPLED BY: Merrimack Village Dist

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241
SAMPLE LOCATION: 1531010-510 (TP-7/8 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 01/20/2026 11:18AM
DATE & TIME RECEIVED: 01/20/2026 03:53PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 7.7° CELSIUS
CLIENT JOB #:

BAR CODE:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Perfluoro-n-[1,2,3,4-13C4]butanoic acid	89	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[1,2-13C2]dodecanoic acid	91	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[13C8]octanoic acid	90	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Perfluoro-n-[13C9]nonanoic acid	93	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate	131	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate	95	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate	74	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Sodium perfluoro-[13C8]octanesulfonate	104	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate	110	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM
Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate	108	%	✓			50-200%	EPA 533 - IDA	SH-NH	01/22/2026 07:06PM




Donald A. D'Anjou, Ph. D.
 Laboratory Director

