

Laboratory Report

Merrimack Village Dist
2 Greens Pond Rd
Merrimack, NH 03054

Date Printed: 02/26/2026
Work Order #: 2602-03514
Client Job #:
Date Received: 02/20/2026
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

Eurofins Auburn:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210

Eurofins Derry:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038

Eurofins Ayer:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432


ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- ND: Non-detect. Results reported as Non-Detect (ND) have been evaluated down to the concentration listed in the MDL column.
- Eurofins Derry, Eurofins Auburn and Eurofins Ayer's accreditations can be found on the website below.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: J = Estimated concentration.**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.








Donald A. D'Anjou, Ph. D.
Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-001
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-008 (MVD-2 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:33AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|--|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF30NS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorobutanesulfonic Acid (PFBS)* | 3.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorobutanoic Acid (PFBA)* | 2.62 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-001
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-008 (MVD-2 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes | ✓ |
| Fails EPA Primary | ⊗ |
| Fails EPA Secondary | ⚠ |
| Fails State Guideline | ✗ |
| Attention | ⚠ |

DATE & TIME COLLECTED: 02/20/2026 10:33AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoroheptanoic acid (PFHpA)* | 3.21 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | 1.06 | ng/L | ✓ | J | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorohexanoic acid (PFHxA)* | 3.79 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorooctanesulfonic acid (PFOS)* | 2.49 | ng/L | ✓ | | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluorooctanoic acid (PFOA)* | 16.9 | ng/L | ✗ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoropentanoic acid (PFPeA)* | 2.62 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 07:54PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 82 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 77 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 84 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |








Donald A. D'Anjou
 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-001
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-008 (MVD-2 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:33AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 92 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[13C8]octanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Perfluoro-n-[13C9]nonanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 153 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 97 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Sodium perfluoro-[13C8]octanesulfonate | 101 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 102 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 07:54PM |




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT






DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-002
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-012 (MVD 9 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026

LAB ID#: 1015

EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:34AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorobutanesulfonic Acid (PFBS)* | 3.80 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorobutanoic Acid (PFBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-002
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-012 (MVD 9 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes | ✓ |
| Fails EPA Primary | ⊗ |
| Fails EPA Secondary | ⚠ |
| Fails State Guideline | ✗ |
| Attention | ⚠ |

DATE & TIME COLLECTED: 02/20/2026 10:34AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoroheptanoic acid (PFHpA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | 1.07 | ng/L | ✓ | J | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorohexanoic acid (PFHxA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorooctanesulfonic acid (PFOS)* | 1.75 | ng/L | ✓ | J | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluorooctanoic acid (PFOA)* | 4.98 | ng/L | ✓ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoropentanoic acid (PFPeA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:08PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 86 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 92 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 81 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 89 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-002
SAMPLED BY: Miner Jr., Ronald
SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-012 (MVD 9 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:34AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 101 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 97 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[13C8]octanoic acid | 98 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Perfluoro-n-[13C9]nonanoic acid | 95 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 89 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 172 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 99 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Sodium perfluoro-[13C8]octanesulfonate | 99 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 103 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:08PM |









Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-003
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-512 (TP-2/9 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:41AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorobutanesulfonic Acid (PFBS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorobutanoic Acid (PFBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-003
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-512 (TP-2/9 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:41AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoroheptanoic acid (PFHpA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | <2.00 | ng/L | ✓ | | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorohexanoic acid (PFHxA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorooctanesulfonic acid (PFOS)* | <2.00 | ng/L | ✓ | | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluorooctanoic acid (PFOA)* | <2.00 | ng/L | ✓ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoropentanoic acid (PFPeA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:22PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 97 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 102 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 103 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 107 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 99 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-003
SAMPLED BY: Miner Jr., Ronald

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-512 (TP-2/9 treated)

EPA ID#: 1531010

DATE & TIME COLLECTED: 02/20/2026 10:41AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 102 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 106 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 100 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[13C8]octanoic acid | 105 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Perfluoro-n-[13C9]nonanoic acid | 105 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 105 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 122 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 110 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Sodium perfluoro-[13C8]octanesulfonate | 112 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 115 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 112 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:22PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-004
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-011 (MVD-4R raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:17AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorobutanesulfonic Acid (PFBS)* | 6.18 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorobutanoic Acid (PFBA)* | 5.33 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-004
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-011 (MVD-4R raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:17AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoroheptanoic acid (PFHpA)* | 12.0 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | 3.07 | ng/L | ✓ | | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorohexanoic acid (PFHxA)* | 15.1 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorooctanesulfonic acid (PFOS)* | 4.27 | ng/L | ✓ | | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluorooctanoic acid (PFOA)* | 75.1 | ng/L | ✗ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoropentanesulfonic acid (PFPeS)* | 0.633 | ng/L | | J | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoropentanoic acid (PFPeA)* | 10.5 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:35PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 82 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 76 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 82 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-004
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-011 (MVD-4R raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:17AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[13C8]octanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Perfluoro-n-[13C9]nonanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 85 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 141 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 92 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Sodium perfluoro-[13C8]octanesulfonate | 100 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 100 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:35PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-005
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-005 (MVD-5 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:18AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | 0.651 | ng/L | | J | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorobutanesulfonic Acid (PFBS)* | 5.88 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorobutanoic Acid (PFBA)* | 5.03 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-005
SAMPLED BY: Miner Jr., Ronald
SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-005 (MVD-5 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes | ✓ |
| Fails EPA Primary | ⊗ |
| Fails EPA Secondary | ▼ |
| Fails State Guideline | ✕ |
| Attention | ⚠ |

DATE & TIME COLLECTED: 02/20/2026 11:18AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoroheptanoic acid (PFHpA)* | 9.03 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | 2.54 | ng/L | ✓ | | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorohexanoic acid (PFHxA)* | 12.0 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorooctanesulfonic acid (PFOS)* | 1.73 | ng/L | ✓ | J | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluorooctanoic acid (PFOA)* | 47.3 | ng/L | ✕ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoropentanoic acid (PFPeA)* | 8.58 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 08:49PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 79 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 83 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |









Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-005
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-005 (MVD-5 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:18AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 88 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 94 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[13C8]octanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Perfluoro-n-[13C9]nonanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 88 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 125 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Sodium perfluoro-[13C8]octanesulfonate | 103 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 105 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 89 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 08:49PM |




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT






DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-006
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-509 (TP-4/5 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026

LAB ID#: 1015

EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:11AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorobutanesulfonic Acid (PFBS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorobutanoic Acid (PFBA)* | 1.15 | ng/L | | J | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-006
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-509 (TP-4/5 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:11AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoroheptanoic acid (PFHpA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | <2.00 | ng/L | ✓ | | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorohexanoic acid (PFHxA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorooctanesulfonic acid (PFOS)* | <2.00 | ng/L | ✓ | | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluorooctanoic acid (PFOA)* | <2.00 | ng/L | ✓ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoropentanoic acid (PFPeA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:02PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 69 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 81 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 80 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 74 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 69 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-006
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-509 (TP-4/5 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 11:11AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 66 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 72 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 82 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[13C8]octanoic acid | 74 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Perfluoro-n-[13C9]nonanoic acid | 76 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 102 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Sodium perfluoro-[13C8]octanesulfonate | 98 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 103 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 101 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:02PM |









Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-007
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-007 (MVD-7 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 09:45AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorobutanesulfonic Acid (PFBS)* | 2.65 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorobutanoic Acid (PFBA)* | 2.50 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-007
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-007 (MVD-7 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 09:45AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoroheptanoic acid (PFHpA)* | 2.73 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | 1.27 | ng/L | ✓ | J | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorohexanoic acid (PFHxA)* | 2.28 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorooctanesulfonic acid (PFOS)* | 2.71 | ng/L | ✓ | | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluorooctanoic acid (PFOA)* | 22.3 | ng/L | ✗ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoropentanoic acid (PFPeA)* | 1.91 | ng/L | | J | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:16PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 88 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 95 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 84 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 88 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |




Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-007
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-007 (MVD-7 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes | ✓ |
| Fails EPA Primary | ⊗ |
| Fails EPA Secondary | ⚠ |
| Fails State Guideline | ✗ |
| Attention | ⚠ |

DATE & TIME COLLECTED: 02/20/2026 09:45AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 102 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 101 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[13C8]octanoic acid | 101 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Perfluoro-n-[13C9]nonanoic acid | 97 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 89 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 194 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 105 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Sodium perfluoro-[13C8]octanesulfonate | 104 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 104 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 87 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:16PM |








Donald A. D'Anjou
 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-008
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-009 (MVD-8 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 09:50AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorobutanesulfonic Acid (PFBS)* | 2.45 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorobutanoic Acid (PFBA)* | 1.91 | ng/L | | J | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |




 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-008
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-009 (MVD-8 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes | ✓ |
| Fails EPA Primary | ⊗ |
| Fails EPA Secondary | ▼ |
| Fails State Guideline | ✕ |
| Attention | ⚠ |

DATE & TIME COLLECTED: 02/20/2026 09:50AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoroheptanoic acid (PFHpA)* | 2.87 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | 1.20 | ng/L | ✓ | J | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorohexanoic acid (PFHxA)* | 2.59 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorooctanesulfonic acid (PFOS)* | 1.49 | ng/L | ✓ | J | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluorooctanoic acid (PFOA)* | 21.2 | ng/L | ✕ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoropentanoic acid (PFPeA)* | 1.90 | ng/L | | J | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:30PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 84 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 83 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 88 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 78 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 83 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |








Donald A. D'Anjou
 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-008
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-009 (MVD-8 raw)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 09:50AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 97 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 95 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 85 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[13C8]octanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Perfluoro-n-[13C9]nonanoic acid | 93 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 85 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 188 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 100 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Sodium perfluoro-[13C8]octanesulfonate | 98 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 100 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 84 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:30PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-009
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-510 (TP-7/8 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:00AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------|---------|----------------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11CI-PF30UdS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| 1H,1H,2H,2H-Perfluorohexanesulfonic acid (4:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Date Extracted | - | | | | | No Limit | EPA 533 | TF-NH | 02/24/2026 11:46AM |
| Hexafluoropropylene oxide dimer acid (HFPO-DA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-3-methoxypropanoic acid (PFMPA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-4-methoxybutanoic acid (PFMBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorobutanesulfonic Acid (PFBS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorobutanoic Acid (PFBA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |









 Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-009
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-510 (TP-7/8 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:00AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|------|----------|---------------|---------|----------------------|
| Perfluorodecanoic Acid (PFDA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorododecanoic acid (PFDoA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoroheptanesulfonic acid (PFHpS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoroheptanoic acid (PFHpA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorohexanesulfonic Acid (PFHxS)* | <2.00 | ng/L | ✓ | | 2.00 | 18 ng/L | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorohexanoic acid (PFHxA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorononanoic acid (PFNA)* | <2.00 | ng/L | ✓ | | 2.00 | 11 ng/L | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorooctanesulfonic acid (PFOS)* | <2.00 | ng/L | ✓ | | 2.00 | 15 ng/L | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluorooctanoic acid (PFOA)* | <2.00 | ng/L | ✓ | | 2.00 | 12 ng/L | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoropentanesulfonic acid (PFPeS)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoropentanoic acid (PFPeA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| Perfluoroundecanoic acid (PFUnA)* | <2.00 | ng/L | | | 2.00 | No Limit | EPA 533 | SH-NH | 02/24/2026 09:43PM |
| 2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy-13C3)propanoic acid | 91 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[1,2,3,4,5-13C5]pentanoic acid | 97 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |









Donald A. D'Anjou, Ph. D.
 Laboratory Director

DRINKING WATER NON COMPLIANCE REPORT

DATE PRINTED: 02/26/2026
SAMPLE ID #: 2602-03514-009
SAMPLED BY: Miner Jr., Ronald

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: Merrimack Village Dist
SYSTEM TOWN: Merrimack
SAMPLE AGENT #: 603-424-9241 x107
SAMPLE LOCATION: 1531010-510 (TP-7/8 treated)

CHEMICAL RESULTS FOR THE QUARTER 2026
LAB ID#: 1015
EPA ID#: 1531010

| Legend | |
|-----------------------|---|
| Passes |  |
| Fails EPA Primary |  |
| Fails EPA Secondary |  |
| Fails State Guideline |  |
| Attention |  |

DATE & TIME COLLECTED: 02/20/2026 10:00AM
DATE & TIME RECEIVED: 02/20/2026 12:34PM
WATER SYS TYPE: Community
RECEIPT TEMP: ON ICE 8.6° CELSIUS
CLIENT JOB #:

BAR CODE:

| Test Description | Result | Test Units | Pass /Fail | DQ Flag | RL | Limit | Method | Analyst | Date & Time Analyzed |
|---|--------|------------|------------|---------|----|---------|---------------|---------|----------------------|
| Perfluoro-n-[1,2,3,4-13C4]butanoic acid | 90 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[1,2,3,4-13C4]heptanoic acid | 92 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[1,2-13C2]dodecanoic acid | 89 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[13C8]octanoic acid | 94 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Perfluoro-n-[13C9]nonanoic acid | 92 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]decane sulfonate | 88 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]hexane sulfonate | 104 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]octane sulfonate | 94 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Sodium perfluoro-[13C8]octanesulfonate | 96 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Sodium perfluoro-1-[1,2,3-13C3]hexanesulfonate | 96 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |
| Sodium perfluoro-1-[2,3,4-13C3]butanesulfonate | 95 | % | ✓ | | | 50-200% | EPA 533 - IDA | SH-NH | 02/24/2026 09:43PM |




Donald A. D'Anjou, Ph. D.
 Laboratory Director

